

Certificate of compliance

Applicant: Zhejiang Chisage New Energy Technology Co., Ltd.
No. 1828, Fuqing South Road, Panhuo Street, Yinzhou District, Ningbo City, Zhejiang Province,
315000
China

Product: Photovoltaic and battery inverter (Hybrid-Inverter)

Model: Jup-10G2-LE, Jup-8G2-LE, Jup-6G2-LE, Jup-5G2-LE

The device is designed to work as a generation unit of the type: A

Inverter for single-phase parallel connection to the public grid. The network monitoring and disconnection device is an integral part of the above-mentioned model.

Applied rules and standards:

EN 50549-1:2019/A1:2023

Requirements for parallel connection of installations with distribution networks - Part 1: Connection to an LV distribution network - Production of installations up to and including Type B

- 4.4 Normal operating range
- 4.5 Immunity to disturbances
- 4.6 Active response to frequency deviation
- 4.7 Power response to voltage variations and voltage changes
- 4.8 EMC and power quality
- 4.9 Interface protection
- 4.10 Connection and starting to generate electrical power
- 4.11 Ceasing and reduction of active power on set point
- 4.13 Requirements regarding single fault tolerance of interface protection system and interface switch

EN 50549-10:2022

Requirements for generating plants to be connected in parallel with distribution networks - Part 10: Tests for conformity assessment of generating units

Commission Regulation (EU) 2016/631 of 14 April 2016

Establishing a network code on requirements for grid connection of generators (NC RFG).
Type approval for generation units to use in Type A plants.

At the time of issue of this certificate, the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

Report number: CQDL-ESH-P24070577-3

Certificate number: U24-1057

Certification Program: NSOP-0032-DEU-ZE-V10

Date of issue: 2024-11-08

Accreditation

